



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
400 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Board of Education, Skillman, NJ
PAS Project ID : P22-04082

Matrix : Drinking Water
Report Date : 5/23/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-04082-01	BOE- Field Blank-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:39	5/17/22 17:14
P22-04082-02	BOE- 1-Kitchen-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:40	5/17/22 17:18
P22-04082-03	BOE- 1-H Conference Rm-WC1-P	Lead	22.1	ug/L	2	4.00	1.80	15.0 *	SM 3113 B	5/17/22 06:41	5/17/22 17:25
P22-04082-04	BOE- 1-H Conference Rm-WC2-P	Lead	15.6	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:42	7/17/22 17:29

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director