



## CERTIFICATE OF ANALYSIS

**Customer :** PARS Environmental  
500 Horizon Drive, Suite 540  
Robbinsville Twp, NJ 08691

**Project ID :** Board of Education, 1016 CR-601, Montgomery, NJ  
**PAS Project ID :** P22-09916

**Matrix :** Drinking Water  
**Report Date :** 8/26/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-09916-01	BOE-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/25/22 05:46	8/25/22 15:13
P22-09916-02	BOE-1-H Conference Rm-WC1-R	Lead	3.95	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/25/22 05:48	8/25/22 15:18
P22-09916-03	BOE-1-H Conference Rm-WC2-R	Lead	3.68	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/25/22 05:49	8/25/22 15:22

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

\* Federal Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Mark D. Feitelson, Lab. Director