



# CERTIFICATE OF ANALYSIS

**Customer :** PARS Environmental  
400 Horizon Drive, Suite 540  
Robbinsville Twp, NJ 08691

**Project ID :** Montgomery Lower Middle School, Skillman, NJ  
**PAS Project ID :** P22-04133

**Matrix :** Drinking Water  
**Report Date :** 5/27/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-04133-01	LMS-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:38	5/18/22 14:28
P22-04133-02	LMS-1-Kitchen-FPI-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:39	5/18/22 14:39
P22-04133-03	LMS-1-Kitchen-FP2-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 05:41	5/18/22 14:54
P22-04133-04	LMS-1-Kitchen-IM-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:42	5/18/22 14:57
P22-04133-05	LMS-1-Kitchen-FP3-P	Lead	1.94 J	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:43	5/18/22 15:01
P22-04133-06	LMS-1-Kitchen-FP4-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:44	5/18/22 15:04
P22-04133-07	LMS-1-Life Skills Rm-CF-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 05:45	5/18/22 15:08
P22-04133-08	LMS-1-Multi Purpose Rm-WCI-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:46	5/18/22 15:11
P22-04133-09	LMS-1-Multi Purpose Rm-WC2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:47	5/18/22 15:22
P22-04133-10	LMS-1-Boys Locker Rm-WC-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:50	5/18/22 15:26
P22-04133-11	LMS-1-Girls Locker Rm-WC-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 05:51	5/18/22 15:30
P22-04133-12	LMS-1-Gym-WCI-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:52	5/18/22 15:33
P22-04133-13	LMS-1-Gym-WC2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:53	5/18/22 15:37
P22-04133-14	LMS-1-MO-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 05:54	5/18/22 15:41
P22-04133-15	LMS-1-H MO-WCI-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 05:56	5/18/22 15:45
P22-04133-16	LMS-1-H MO-WC2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:00	5/18/22 15:48
P22-04133-17	LMS-1-H MO-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:01	5/18/22 15:52
P22-04133-18	LMS-1-H Nurse-WCI-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:03	5/18/22 15:56
P22-04133-19	LMS-1-H Nurse-WC2-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 06:04	5/18/22 16:07
P22-04133-20	LMS-1-Nurse-NSI-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:05	5/18/22 16:11
P22-04133-21	LMS-1-Nurse-NS2-P	Lead	1.44 J	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:06	5/18/22 16:14
P22-04133-22	LMS-1-Nurse-BF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:07	5/18/22 16:29
P22-04133-23	LMS-1-Band Rm-CF-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 06:09	5/18/22 16:32
P22-04133-24	LMS-1-H DIO-WCI-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:10	5/18/22 16:36
P22-04133-25	LMS-1-H D10-WC2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:11	5/18/22 16:39
P22-04133-26	LMS-1-D-1-ECI-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:12	5/18/22 16:50
P22-04133-27	LMS-1-D-1-EC2-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 06:13	5/18/22 16:54
P22-04133-28	LMS-1-D-1-EC3-P	Lead	1.37 J	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:14	5/18/22 16:57
P22-04133-29	LMS-1-D-1-EC4-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:15	5/18/22 17:01
P22-04133-30	LMS-1-D-1-EC5-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:16	5/18/22 17:04
P22-04133-31	LMS-1-D-1-EC6-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 06:17	5/18/22 17:08
P22-04133-32	LMS-1-D-1-EC7-P	Lead	1.72 J	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:18	5/18/22 17:12
P22-04133-33	LMS-1-H CPOD-WC2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:20	5/18/22 17:15
P22-04133-34	LMS-1-H C12-WC1	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:21	5/18/22 17:19
P22-04133-35	LMS-1-H C12-WC2	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 06:22	5/18/22 18:07
P22-04133-36	LMS-1-H B3-WCI	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:23	5/18/22 18:18
P22-04133-37	LMS-1-H B3-WC2	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:25	5/18/22 18:22
P22-04133-38	LMS-1-H APOD-WCI-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:30	5/18/22 18:25
P22-04133-39	LMS-1-H APOD-WC2-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 06:31	5/18/22 18:29
P22-04133-40	LMS-1-H A12-WC1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3133 B	5/18/22 06:32	5/18/22 18:32
P22-04133-41	LMS-1-H A12-WC2-P	Lead	ND	ug/L	1	2.00	0.90	15.0 *	SM 3133 B	5/18/22 06:34	5/18/22 18:36

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- \* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director