



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Montgomery High School, 1016 Rt. 601, Skillman, NJ

PAS Project ID : P23-00141

Matrix : Drinking Water

Report Date : 1/12/2023

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P23-00141-01	MHS-Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/6/23 06:00	1/11/23 11:37
P23-00141-02	MHS-1-Pool-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/6/23 06:00	1/11/23 11:41
P23-00141-03	MHS-1-Pool-WC-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	1/6/23 06:02	1/11/23 11:45

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD | TOMS RIVER, NJ 08755 | PHONE 732-914-1515 | FAX 732-914-1818

CHAIN
OF
CUSTODY

Project # 662-61

Customer:	PARS Environmental
Address:	500 Horizon Drive, Suite 540
	Robbinsville, NJ 08691
Phone:	(609) 890-7277 Office (609) 672-2557 Cell Jessica Perrini

School Name:	Montgomery High School
School Address:	1016 Rt 60, Skillman, NJ
Sampled By:	Thomas Helmich
Print Name:	Thomas Helmich
RESULTS TO:	JPerrini@montrose-env.com

Sample #	Sample ID Location	Date Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Containers	Glass or Plastic	Analysis	LAB ID
1	MHS - Field Blank	6:00	DW	Grab	N	N	1	250 ml Plastic	Lead	P23-00141-01
2	MHS-1-POOL-BT-P	6:00	DW	Grab	N	N	1	250 ml Plastic	Lead	↓ -03
3	MHS-1-POOL-WC-P	6:02	DW	Grab	N	N	1	250 ml Plastic	Lead	P23-00141-03
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	
			DW	Grab	N	N	1	250 ml Plastic	Lead	

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 1	Deliverables:	PDF Std. X	PDF Reduce	PDF Full	EDD	Date/Time Preserved with HNO3:
-------------	---------------	------------	------------	----------	-----	--------------------------------

MATRIX CODES:	GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):	PRESERVATION CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other
----------------------	--	--

	Print Name:	Signature:	Company:	Date & Time
Relinquished:	Thomas Helmich	Thomas Helmich	PARS	1/6/23
Received:	Lynn Souza	Lynn Souza	PARS	09:00
Relinquished:				
Received:				
Relinquished:				
Received:				