



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Orchard Hill Elementary East, 244 Orchard Rd.
PAS Project ID : P22-04081

Matrix : Drinking Water
Report Date : 5/23/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-04081-01	OHE-Field Blank-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:04	5/17/22 14:57
P22-04081-02	OHE-1-H Gym-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:05	5/17/22 15:00
P22-04081-03	OHE-1-H Gym-WC-P	Lead	1.17 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:08	5/17/22 15:14
P22-04081-04	OHE-1-H 75-WC-P	Lead	1.31 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:08	5/17/22 15:18
P22-04081-05	OHE-1-H 75-DW1-P	Lead	8.43	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:09	5/17/22 15:29
P22-04081-06	OHE-1-H 75-DW2-P	Lead	5.61	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:09	5/17/22 15:33
P22-04081-07	OHE-1-H 150-WC-P	Lead	0.970 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:09	5/17/22 15:36
P22-04081-08	OHE-1-H 150-DW1-P	Lead	3.93	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:10	5/17/22 15:40
P22-04081-09	OHE-1-H 150-DW2-P	Lead	7.43	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:11	5/17/22 15:43
P22-04081-10	OHE-1-MO-WC-P	Lead	0.900 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:12	5/17/22 15:47
P22-04081-11	OHE-1-MO-TL-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:12	5/17/22 15:51
P22-04081-12	OHE-1-H 52-BT-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:14	5/17/22 15:54
P22-04081-13	OHE-1-H 52-WC1-P	Lead	1.04 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:14	5/17/22 15:58
P22-04081-14	OHE-1-H 52-WC2-P	Lead	0.970 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:15	5/17/22 16:02
P22-04081-15	OHE-1-Nurse-NS1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:16	5/17/22 16:13
P22-04081-16	OHE-1-Nurse-NS2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:16	5/17/22 16:17
P22-04081-17	OHE-1-Nurse-BF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:17	5/17/22 16:20
P22-04081-18	OHE-1-39-TLounge-TL-P	Lead	0.970 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:19	5/17/22 16:24
P22-04081-19	OHE-1-39-TLounge-WC-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:19	5/17/22 16:28
P22-04081-20	OHE-1-Kitchen-KT-P	Lead	14.6	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:20	5/17/22 16:39
P22-04081-21	OHE-1-Kitchen-FP1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:20	5/17/22 16:42
P22-04081-22	OHE-1-Kitchen-FP2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:21	5/17/22 17:04
P22-04081-23	OHE-1-Kitchen-FP3-P	Lead	1.04 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:21	5/17/22 17:07
P22-04081-24	OHE-1-H Fac Work Rm-DW2-P	Lead	5.07	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 07:22	5/17/22 17:11

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Orchard Hill Elementary School, 244 Orchard Rd.
PAS Project ID : P22-04085

Matrix : Drinking Water
Report Date : 5/23/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-04085-01	OHW-Field Blank-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:30	5/18/22 13:36
P22-04085-02	OHW-1-H 108-DW-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:31	5/18/22 13:40
P22-04085-03	OHW-1-108-CF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:32	5/18/22 13:44
P22-04085-04	OHW-1-108-SB-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:32	5/18/22 13:47
P22-04085-05	OHW-1-107-CF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:33	5/18/22 13:51
P22-04085-06	OHW-1-107-SB-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:33	5/18/22 13:55
P22-04085-07	OHW-1-106-CF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:35	5/18/22 13:58
P22-04085-08	OHW-1-106-SB-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:35	5/18/22 14:02
P22-04085-09	OHW-1-105-CF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:38	5/18/22 14:19
P22-04085-10	OHW-1-105-SB-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:38	5/18/22 14:33
P22-04085-11	OHW-1-104-CF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:40	5/18/22 14:37
P22-04085-12	OHW-1-104-SB-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:40	5/18/22 14:40
P22-04085-13	OHW-1-103-CF-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:42	5/18/22 14:44
P22-04085-14	OHW-1-103-SB-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:42	5/18/22 14:48
P22-04085-15	OHW-1-102-CF1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:43	5/18/22 14:59
P22-04085-16	OHW-1-102-SB1-P	Lead	1.10 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:43	5/18/22 15:02
P22-04085-17	OHW-1-102-CF2-P	Lead	1.81 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:45	5/18/22 15:06
P22-04085-18	OHW-1-101-CF1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:49	5/18/22 15:10
P22-04085-19	OHW-1-101-SB1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:49	5/18/22 15:13
P22-04085-20	OHW-1-101-CF2-P	Lead	8.95	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:50	5/18/22 15:17
P22-04085-21	OHW-1-101-SB2-P	Lead	1.10 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:50	5/18/22 15:21
P22-04085-22	OHW-1-109-DW-P	Lead	1.81 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:55	5/18/22 15:25
P22-04085-23	OHW-1-111-CF-P	Lead	127	ug/L	20	40.0	18.0	15.0 *	SM 3113 B	5/17/22 06:56	5/18/22 15:48
P22-04085-24	OHW-1-H 119-DW1-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:57	5/18/22 15:52
P22-04085-25	OHW-1-H 119-DW2-P	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	5/17/22 06:58	5/18/22 15:56

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director