



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Village Elementary School, 100 Main Boulevard
PAS Project ID : P22-04084

Matrix : Drinking Water
Report Date : 5/23/2022

| PAS Sample ID | Client ID | Analysis | Results | Units | DF | PQL | MDL | MCL | Method | Date Sampled | Date Analyzed |
|---------------|-----------------------------|----------|---------|-------|----|------|-------|--------|-----------|---------------|---------------|
| P22-04084-01 | VES-Field Blank-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:25 | 5/18/22 10:30 |
| P22-04084-02 | VES-1-Get Better Rm-CF-P | Lead | 0.950 J | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:26 | 5/18/22 10:34 |
| P22-04084-03 | VES-1-Get Better Rm-SB-P | Lead | 4.90 | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:27 | 5/18/22 11:02 |
| P22-04084-04 | VES-1-H Special Ed-WC1-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:29 | 5/18/22 11:05 |
| P22-04084-05 | VES-1-H Special Ed-WC2-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:30 | 5/18/22 11:09 |
| P22-04084-06 | VES-1-109-CF-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:31 | 5/18/22 11:13 |
| P22-04084-07 | VES-1-109-SB-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:32 | 5/18/22 11:17 |
| P22-04084-08 | VES-1-108-CF-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:33 | 5/18/22 11:21 |
| P22-04084-09 | VES-1-108-SB-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:34 | 5/18/22 11:25 |
| P22-04084-10 | VES-1-111-CF-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:35 | 5/18/22 11:30 |
| P22-04084-11 | VES-1-111-SB-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:36 | 5/18/22 11:34 |
| P22-04084-12 | VES-1-113-CF-P | Lead | 8.64 | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:37 | 5/18/22 11:46 |
| P22-04084-13 | VES-1-113-SB-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:38 | 5/18/22 11:50 |
| P22-04084-14 | VES-1-Main Entrance-BT-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:39 | 5/18/22 11:54 |
| P22-04084-15 | VES-1-100-CF-P | Lead | 1.38 J | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:41 | 5/18/22 11:58 |
| P22-04084-16 | VES-1-100-SB-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:42 | 5/18/22 12:03 |
| P22-04084-17 | VES-1-H 101-WC1-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:43 | 5/18/22 12:07 |
| P22-04084-18 | VES-1-H 101-WC2-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:44 | 5/18/22 12:11 |
| P22-04084-19 | VES-1-Band Rm-CF-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:45 | 5/18/22 12:15 |
| P22-04084-20 | VES-1-101-CF-P | Lead | 2.48 | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:46 | 5/18/22 12:19 |
| P22-04084-21 | VES-1-101-SB-P | Lead | 3.14 | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:47 | 5/18/22 12:31 |
| P22-04084-22 | VES-1-104-CF-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:48 | 5/18/22 12:47 |
| P22-04084-23 | VES-1-104-SB-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:49 | 5/18/22 12:51 |
| P22-04084-24 | VES-1-105-CF-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:50 | 5/18/22 12:55 |
| P22-04084-25 | VES-1-105-SB-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:51 | 5/18/22 12:59 |
| P22-04084-26 | VES-1-Nurse-NS1-P | Lead | 1.82 J | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:52 | 5/18/22 13:03 |
| P22-04084-27 | VES-1-Nurse-NS2-P | Lead | 6.44 | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:53 | 5/18/22 13:15 |
| P22-04084-28 | VES-1-Nurse-BF-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:54 | 5/18/22 13:19 |
| P22-04084-29 | VES-1-T Lounge-TL-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:56 | 5/18/22 13:23 |
| P22-04084-30 | VES-1-Cafe-BT-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:57 | 5/18/22 13:27 |
| P22-04084-31 | VES-1-Cafe-WC1-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 05:58 | 5/18/22 13:31 |
| P22-04084-32 | VES-1-Kitchen-FP-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 06:00 | 5/18/22 13:35 |
| P22-04084-33 | VES-1-Multi Purpose Rm-WC-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 06:02 | 5/18/22 13:39 |
| P22-04084-34 | VES-1-H 208-WC1-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 06:04 | 5/18/22 13:44 |
| P22-04084-35 | VES-1-H 208-WC2-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 06:05 | 5/18/22 14:11 |
| P22-04084-36 | VES-1-H 307-WC1-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 06:08 | 5/18/22 14:15 |
| P22-04084-37 | VES-1-H 307-WC2-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 06:09 | 5/18/22 14:19 |
| P22-04084-38 | VES-1-H 309-WC1-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 06:10 | 5/18/22 14:23 |
| P22-04084-39 | VES-1-H 309-WC2-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 06:11 | 5/18/22 14:27 |

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

- PQL = Practical Quantitation Limit
- MDL = Minimum Detection Limit
- MCL = Maximum Contaminant Level
- DF = Dilution Factor
- ND = Analyzed for but not detected
- J = Estimated result
- * Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : PARS Environmental
500 Horizon Drive, Suite 540
Robbinsville Twp, NJ 08691

Project ID : Village Elementary School, 100 Main Boulevard
PAS Project ID : P22-04135

Matrix : Drinking Water
Report Date : 5/23/2022

| PAS Sample ID | Client ID | Analysis | Results | Units | DF | PQL | MDL | MCL | Method | Date Sampled | Date Analyzed |
|---------------|-------------------|----------|---------|-------|----|------|-------|--------|-----------|---------------|---------------|
| P22-04135-01 | VES-Field Blank | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 06:07 | 5/19/22 13:52 |
| P22-04135-02 | VES-1-H 210-WC2-P | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 5/17/22 06:08 | 5/19/22 13:56 |

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director